

## Request For Information #

60

Received by PE&amp;S:

24 / 05 / 2023

Received By HEC

29 / 05 / 2023

Request by : PE&amp;S

Planner

Manager

HOD

Coordinator

Time  
of  
work

production time



URGENT



no production



WORK IS PLANNED



shutdown



FOR BUDGETING

Type  
of  
work

Utility



Fire Fighting



Construction



Safety



Mechanical



Other

Vasilyev V.

Fedosov A.

Yakovlev E.

24 / 05 / 2023

\_\_ / \_\_ / 2023

29 / 05 / 2023

\_\_ / \_\_ / 2023

Subject

Diagnosis and repair of air conditioning system

**1. Place / Расположение:**

Shop: Stamping shop

Place (line/columns): Office Stamping and Welding shops and roof ✓

Equipment: Air conditioning system LG ARUN120LTE4

**2. Work description / Описание работ:**Perform diagnosis of air conditioning system *and make a report!*

Perform repair of air conditioning system according to diagnosis report

Check the volume of freon, refuel if necessary

Выполнить диагностику системы кондиционирования *и сделать отчет!*

Выполнить ремонт системы кондиционирования, согласно отчету о диагностике

Проверить уровень фреона, в случае необходимости дозаправить

**3. Attachments / Приложение**Error on the  
Control panel

Error on the external unit



Checking Freon pressure



Error CH 43 - Malfunction of the high pressure sensor

Checking Freon pressure -  
0,5 bar Not OK**4. Contact person:** Vasilyev V

telephone # 0249

Please provide the price &amp; schedule for required work.

Checked by PE&amp;S

PE&amp;S Comments:

Specialist

Manager

HOD

Coordinator

E. Yakovlev

\_\_ / \_\_ / 2023

\_\_ / \_\_ / 2023

\_\_ / \_\_ / 2023

\_\_ / \_\_ / 2023

Deadline

\_\_ / \_\_ / 2023